

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220422
Address: 520 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, October 05, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-land electrical to box at East garage wall, kitchen wall-kitchen/garage wall, pan off at furred down for return air and not just tyvek paper, fireblock on non air return stud cavities by providing solid blocking at soffit line-seal plumbing floor penetrations at great room chase-fireblock plumbing chase at great room, seal annular space around plumbing-move electrical above attic access opening garage and protect electrical within 6' of opening-fireblock tub trap 2nd floor bath (see open space where foam has fallen)-nail off joist hangers basement
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: