

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20223181  
Address: 1401 NW RIVER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, October 05, 2022

Informational:  
1 Misc - 10/05/22 30' FOOTING 6"X6" MAT GRID FOR 8' CMU WALL SOUTH OF  
BLEACHERS NEAR TRANSFORMER PAD.  
UFER CLAMP IN CENTER OF FOOTING RUN TO TRANSFORMER PAD -

**Comments:**