

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20223181  
Address: 1401 NW RIVER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Michael Harkins	Partial	Wednesday, October 05, 2022

Informational:  
1 Misc - SE CORNER FIELD # 3 RETAINING WALL OK TO POUR -  
- SW CORNER FIELD # 4 RETAIN WALL OK TO POUR -

Informational:  
2 Misc PRCOM20223181  
9/27/22  
Bleachers Field 1  
(8) footing/piers SW end line B details F2  
Sheet 1-0  
Line A (1) footing piers NE detail F1  
  
Footings for bleacher footings only  
Permit # PRCOM20223476  
Permit # PRCOM20224842  
Ok to pour after phone conversation with  
Joe Frogge 9/17/22 @ 14:19  
  
9/28/22  
Bleachers Field 1  
Line A (7) footing /piers  
  
9/29/22

Bleachers field 1  
Line C (3) footing/piers detail F3  
Line B piers 1 Thru 8 Sonotubes w/ anchor bolts

Informational:

3            Misc

- 10/05/22 30' FOOTING 6"X6" MAT GRID FOR 8' CMU WALL SOUTH OF  
BLEACHERS NEAR TRANSFORMER PAD.  
UFER CLAMP IN CENTER OF FOOTING RUN TO TRANSFORMER PAD -

**Comments:**