



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100137, Building Permit - Commercial
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Partial	Tuesday, April 19, 2011
Partial Correction			
1 MISC		G.E.C. FOR UFER GROUND IN PLACE FOR SECOND FOOTING POUR	

Footing Inspection - Commercial	John Borns	Partial	Tuesday, April 19, 2011
--	------------	---------	-------------------------

Corrective Action Required		
1 MISC		SECTIONS APPROVED: NORTH WALL, EAST WALL, SOUTHEAST CORNER WEST 20'; REMAINDER OF EXTERIOR WALL FOOTING + INTERIOR FOOTING.

Comments: NO FUTURE INSPECTIONS WITHOUT PERMIT PRINTS ON JOBSITE, SITE ADDRESS LABEL POSTED AND ALL ACTIVE M/E/P SUBCONTRACTORS LISTED ON PERMIT.