

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213109

Address: 3723 SW WALSH DR, LEES SUMMIT, MO 640823725 SW WALSH DR, LEES SUMMIT, MO 640823727
SW WALSH DR, LEES SUMMIT, MO 640823721 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Not Ready	Wednesday, October 05, 2022

Corrective Action Required:

1	Misc	-splash blocks, min 36" discharge from foundation, see sump pump discharge lines -resolve inspection fee
---	------	-------------------------------------------------------------------------------------------------------------

UNIT 3727: ok for TCO

UNIT 3721: ok for TCO, this unit is to be used as model

UNIT 3723: ok for TCO

UNIT 3725: ok for TCO

Comments: