

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220892

Address: 1052 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811054 NW BLACK TWIG CIR, LEES SUMMIT, MO  
640811056 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811050 NW BLACK TWIG CIR,  
LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection</b>	Eric Sharp	Passed	Wednesday, October 05, 2022

Informational:

1 Misc

Miller Plumbing performed sanitary sewer tie in on west end of building.  
Using 4" SDR26 pipe, SDR26 adapters/connections and a hard back furnco for  
connection to 6" stub pipe. 10/5/22 ES

**Comments:**