

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215066

Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT,  
MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW HOLDBROOKS  
DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ryan Heckman	Passed	Thursday, October 06, 2022

Informational:

1 Misc

8-30-22 RH. Sidewalk was formed up and aggregate was placed and compacted.

9-6-22 RH. Sidewalk already has cracks on 3 panels. There was no expansion joints between any of the sidewalk and approaches.

9-29-22 RH. Sidewalk was removed and reformed. Aggregate was placed and compacted.

10-6-22 RH. Sidewalk meets LS and ADA specification.

**Comments:**