

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214881
Address: 4401 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, October 06, 2022

Corrective Action Required:

1	Misc	-final driveway and sidewalk inspections required, contact development services to schedule -dishwasher outlet requires GFCI protection -basement stairs, handrail height 34"-38" by code, top of handrail over 38" -water pressure regulator required at water line -set electrical ground rod below grade at exterior
---	------	---

Comments: