

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204399
Address: 617 SE 6TH ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John Jackson	Passed	Thursday, October 06, 2022

Informational:

1	Misc	06/24/22 Friday Contractor is required to install one 15" storm pipe or two 12" pipe to continue Storm runoff throughout drain ditch. Contractor will call in another inspection when they ready for pre-inspection.
		08/02/22 Monday As-per Right-way Supervisors Bob Burns storm pipes will not be installed because this cause flooding issues on downhill adjacent properties. Raising the driveways and culver ditches for a more natural runoff of water. These measure should stop sever runoff, erosion of lawn and right-way.
		10/06/22 Thursday JMJ Driveway was passed, but not closed out in August.

Comments: