

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214080

Address: 2005 SW OSAGE DR, LEES SUMMIT, MO 64082 2003 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, October 06, 2022

Corrective Action Required:

1	Misc	-submit as graded plot plan for review and approval
		2003 interior ok
		2005
		-address garage stairs risers greater than 3/8 difference
		-fill egress window well to drain or trim inlet down

Comments: