

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222951
Address: 2125 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Thursday, October 06, 2022

Corrective Action Required:

1	Miscellaneous Correction	SECURE SEC CABLE AT SERVICE PANEL
---	-----------------------------	-----------------------------------

Comments: