

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20214430  
Address: 126 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Michael Harkins	Failed	Friday, October 07, 2022
Corrective Action Required:			
1 Misc		- MAINTAIN GRAVEL FILTER - CLEAN GRAVEL AND DEBRIS FROM STREET	
Corrective Action Required:			
2 DCM1 ESC REQUIRED NO FURTHER INSP		EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.  - MAINTAIN SILT FENCE UNTIL SOD COMPLETE -	
Corrective Action Required:			
3 DCM6 ESC INSP DENIED STREET CLEAN UP		STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED.	
Corrective Action Required:			
4 DCM6 ESC INSP DENIED STREET CLEAN UP		REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED.  CLEAN STREET OF MUD AND DEBRIS	

**Comments:**