

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222409
Address: 2126 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, October 10, 2022

Corrective Action Required:

1	Misc	-install lib in bath 2 to plans and code-NOT DONE -missing joist hangers above bed 2-ADDRESS TRUSS DAMAGED AT HANGER -address over notched floor joisted for 3" dwv in basement near column A-JOIST NOTCHED FOR MASTER SHOWER -address over notched floor joist for dwv below bath 2-FIREBLOCK TUB TRAP
---	------	---

Comments: