

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20220013
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082
Inspected On: Monday, October 10, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 11/9/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Pending	
---	--------------------	---------	--

Corrective Action Required:

1	Misc	SPLASH BLOCKS, MIN 36" DISCHARGE FROM FOUNDATION, WITH SHORTER SPLASH BLOCKS EITHER REPLACE WITH LONGER BLOCKS OR ADD EXTENSIONS TO DOWNSPOUTS TO KICK SPLASH BLOCKS OUT FOR 36" DISCHARGE
---	------	--