

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220902
Address: 520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Adam Nacke	Partial	Monday, October 10, 2022

Informational:
1 Misc 10-10-22 AN. 10" sdr 26 mandrel test . 9.21 mandrel
Existing MH to S1 passed
S1 to S2 passed
S2 to S3 not tested

Comments: