

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20220902  
Address: 520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	Adam Nacke	Partial	Monday, October 10, 2022

Informational:  
1 Misc 10-10-22 AN. 10" sdr 26 mandrel test . 9.21 mandrel  
Existing MH to S1 passed  
S1 to S2 passed

**Comments:**