

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214631
Address: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection	Ryan Heckman	Partial	Monday, October 10, 2022

Informational:

1 Misc

10-10-22 RH. Detention basin fix started today by changing where the structure in the detention basin is. ESS started digging and moving the structure today.

Detention basin structure was moved and aggregate began being placed around box to stop silt from filling up around structure.

Comments: