

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216410  
Address: 2826 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Passed	Tuesday, October 11, 2022

Informational:

1	Misc	-uncover anchor bolt at PFH for inspection -address hanger used for hip rafter above dining/kitchen -cspf nailing at rear of dining address over nailed sheathing, cspf nail pattern not to plans -uncover cover front patio for inspection -address hip rafter connect in master NW wall
---	------	---

-okay to insulate

Informational:

2	Misc	passed per engineer letter.
---	------	-----------------------------

**Comments:**