

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216410  
Address: 2826 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, October 11, 2022

Corrective Action Required:

1	Misc	Erosion control to remain in place and compliance until time of sod -sod -obtain lawn irrigation permit -check water meter at time of sod -hardware at rear slider -fire blocking for engineered I joists in unfinished spaces
---	------	---

**Comments:**