CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20215490

Address: 2812 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

Inspected On: Tuesday, October 11, 2022

Inspected By: Mitchell Schwarz

Expiration Date: 11/10/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection -

Codes Residential

Mitchell Schwarz

Pending

Corrective Action Required:

1 Misc -final grade and sod

-splash blocks and sump pump discharge to extend 36" from

foundation -pay all fees

-check water meter at time of final grade and sod