

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Adam Nacke	Passed	Tuesday, October 11, 2022

Informational:
1 Misc 10-11-22 AN. Did hydro static test on the fire line 8:25 to 10:25 . 2hr at 200 psi passed .

Comments: