

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222242  
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	Adam Nacke	Passed	Tuesday, October 11, 2022

Informational:  
1 Misc 10-11-22 AN. Did hydro static test on the fire line 8:25 to 10:25 . 2hr at 200 psi passed .  
10-11-22 AN fire line was also flushed

**Comments:**