

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Tuesday, October 11, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED
---	-------------	---

	AREA "B" UNITS AND CORRIDOR APPROVED
--	---

Corrective Action Required:

2	SECOND FLOOR	AREA A UNITS AND CORRIDOR APPROVED
---	--------------	---------------------------------------

	AREA B UNITS AND CORRIDOR APPROVED
--	---------------------------------------

Corrective Action Required:

3	FIRST FLOOR	AREA A UNITS AND CORRIDOR APPROVED ECEPT AS NOTED: 129-INCOMPLETE
---	-------------	---

	AREA B -COMMON AREAS INCOMPLETE -Address fire wall damage and penetrations both sides -Seal dead spaces 116-identify white conductors, seal dead space at guest bath, anchor bolts by sgd and at plate breaks,
--	--

117-anchor bolts
119-INCOMPLETE
118-anchor bolts, missing stud at window,
120- remove foam and caulk in corridor, support sec, anchor bolts, seal dead
space,
121-anchor bolts,fireblock ceiling line at mechanical closet
122-anchor bolts

Corrective Action Required:

4 ELEVATOR 1

Corrective Action Required:

5 STAIR TOWER 1 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

6 STAIR TOWER 2 -PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL

Corrective Action Required:

7 STAIR TOWER 3

Corrective Action Required:

8 STAIR TOWER 4

Comments: