

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570
Address: 1120 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	John Jackson	Partial	Tuesday, October 11, 2022

Informational:	
1 Misc	10/11/22 Tuesday JMJ (Central Plumbing Inc.) Engineering from Water Dept. met on-site to assist contractors with direction of how to install new manholes. Existing manholes will be replaced with new Manholes. Water is ok with the stubbing out each manhole and 45 degree fittings at the top and bottom where they need to be to maintain proper clearance from the storm line. Sewer main line is to be line at the bottom of hill as-per (Lee's Summit).

Comments: