

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201365
Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Robb Popp	Failed	Wednesday, October 12, 2022

Informational:

1	Miscellaneous Correction	4/14/22 Email sent to contractor 4/15/22 Emails exchanged with Ashley Ramos from Midwest Sign Company in effort to resolve outstanding permit with no inspections performed 4/29/22 Email sent to Ashley Ramos to check on status 5/20/22 Emailed with Jason Yaeger. Stated he is working to find a company to X-Ray concrete 6/17/22 Follow up email to Jason, no reply
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	-PROVIDE ENGINEERED DOCUMENTATION FOR FOOTING POURED WITH NO INSPECTIONS PER DISCUSSIONS
---	--------------------------	--

Comments: