


October 3, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field Issue of deck beam attachment for Lot #123 Woodside Ridge – 2103 NW Killarney Lane
Lee's Summit, MO 64081 – Permit # PRRES20215616**

Recommended modifications:



- Install Simpson ML28Z angle per detail as shown in image above on both sides of deck.
- Shim gap between ledger and siding as needed for Ledgerloks.

Sincerely,

Bradley Huxol, PE

