

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220169
Address: 2006 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, October 12, 2022

Corrective Action Required:

1 Misc

- midway strap all dwv 2" in diameter or less in stud bays see rec room
- fire block furr down ends in basement see rec room seal penetration W wall
- seal gaps into furr down in basement bath
- add vertical to horizontal fireblocking at bed 4 S wall foam penetration

Comments: