

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220893

Address: 1003 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811005 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811007 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811001 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Patrick Schonfeldt	Failed	Wednesday, October 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	1001 ok
---	--------------------------	---------

1003 Ok

1005

Nail exterior wall sheathing at garage portal
Nail burn clips to top plate throughout
Provide anchor bolt within 12" of end of plate at SGD
Install SGD

1007

Nail burn clips to top plate throughout
Solid block and nail exterior sheathing near front door
Anchor bolt front door
Hold down missing screws corner living room

Comments: