

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215494
Address: 2130 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, October 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	Handrails shall be provide on not less than side of each flight of stairs with four or more risers basement landing (2018 IRC R311.7.8)
---	--------------------------	--

Comments: