

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213784
Address: 2617 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Passed	Thursday, October 13, 2022

Corrective Action Required:

1	Misc	9-29-22 RH. Sidewalk met ADA specification but there were two cracked panels that will need replaced.
		10-3-22 RH. Sidewalk is formed up and aggregate is placed and compacted.
		10-13-22 RH. Sidewalk meets LS and ADA specification.

Comments: