

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO 640823507  
SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES SUMMIT, MO  
640823501 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Ryan Heckman	Partial	Thursday, October 13, 2022

Informational:

1 Misc

10-13-22 RH. Asphalt base started to be placed today when temperature was 51 degrees and rising. 1 lift of 4" base mix was placed with correct temperatures and rolling method. On site testing was completed with passing results. Surface asphalt will be placed tomorrow.

**Comments:**