

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222688
Address: 257 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, October 13, 2022

Corrective Action Required:

1	Misc	-BOND METALLIC GAS LINE BEFORE FIRST CONNECTION TO WARD FLEX -PROVIDE ENGINEER REPORT FOR FRAMING ALTERATIONS AT STAIR WALL LBW BEING REMOVED FOR OPEN LAYOUT DISCUSSED ON SITE
---	------	---

Comments: