CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214264

Address: 4816 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Friday, October 14,

Residential 2022

Corrective Action Required:

1 Misc -Obtain lawn irrigation permit and submit backflow valve test report to city

**the permit application is not completed

-Provide engineer address for deck beam support at house end; deck beam not attached to post with 2 through bolts per code **I talked to the engineer,

Mr. David Mezger. He will reevaluate the deficiencies above

-Provide min 6" clearance from siding and window trim to grade ** build a

rock bed under the window trim to meet the requirement above

-Provide spark rings at all boxes recessed behind combustible wall finish

throughout house **Receptacle boxes in master bedroom

Comments: