

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222561  
Address: 1151 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Friday, October 14, 2022

**Corrective Action Required:**

1	Misc	Inspection of demising wall between 1159 and 1157 and restroom in 1159: -Protect DVW at bottom track with BOCA plates -Install backings for grab bars and fixture
---	------	---

**Comments:**