

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216223
Address: 106 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Partial	Friday, October 14, 2022

Partial Correction:

1	Misc	HOUSE APPROVED
---	------	----------------

PRESSURE TEST GAS LINES AT GENERATOR NOT ON SITE
PAINT GAS LINES TO GENERATOR
Generator installed in future post build
UNDER SEPARATE PERMIT ?

Comments: