

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216223  
Address: 106 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:      | Outcome:  | Date:                    |
|---|-----------------|-----------|--------------------------|
| <b>All Rough Inspection - Residential</b> | Michael Harkins | Not Ready | Friday, October 14, 2022 |

Corrective Action Required:

|   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | Joist hangers missing nails east to west LVL above SGD<br>Strap top plate dining room no corner overlap<br>Seal top plate bed 6 shower/closet |
|---|--------------------------|---|

**Comments:**