

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213806
Address: 3809 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, October 17, 2022

Corrective Action Required:

1	Misc	10/17/22 - GARAGE PFH PORTAL INSPECTION - NAIL SHEATHING EDGES TO BLOCKING -NAIL SHEATHING EDGES TO SILL PLATE AT PORTAL LEGS
---	------	---

Comments: