CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20216395Address:1613 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, October 17, 2022	
Corrective Action Required:				
1 Misc	 -address valley rafter b -provide bearing for 2 2 -complete gas line inst -complete bath fans -complete dwv and hva basement -support pex above bas -tighten all anchor bolt -address over notched -double 2x6 per plans b -anchor bolts to be in t throughout) -fireblock ends of bed -tighten nuts and bolts 	 -complete dwv and hvac in unfinished are of basement -support pex above basement bath -tighten all anchor bolts in basement -address over notched studs in basement at anchor bolts -double 2x6 per plans bed 2 E wall -anchor bolts to be in the middle 1/3 of sill plate see bed 2 sw corner. (Check 		

Comments: