

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20223245  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Partial	Monday, October 17, 2022

Corrective Action Required:

1	Miscellaneous Correction	1A047B-OK 1A056-OK 1A046 - OK 9/6/2 02-14056 - OK 10/3/22 10/10/22 Sterile Storage room 02-1A079 OK
---	-----------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	- 10/17/22 ROOM 02-1A094 FIRE CAULK PENETRATIONS AT MC CABLES TO RACEWAYS & MC ABOVE DOOR LOW VOLT, FIRE CAULK END OF SLEEVES PENETRATING WALL ABOVE DOOR
---	-----------------------------	---

**Comments:**