

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221791
Address: 4717 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Monday, October 17, 2022

Informational:
1 Misc 10-6-22 AN forms are in place and aggregate is present and compacted
10-17-22 AN driveway looks good and meets Ada spec

Comments: