

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215208
Address: 209 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Monday, October 17, 2022

Corrective Action Required:

1	Miscellaneous Correction	NO CITY APPROVED PLANS ON SITE NOT READY THIS LIST IS INCOMPLETE MAY BE ADDED TO WHEN THESE ITEMS ARE ADDRESSED SEAL ALL LOW VOLT UPWARD PENETRATIONS COMPLETE FURR OUTS GARAGE B VENT/HVAC VENT BATH EXHAUST TO DAYLIGHT FIRE BLOCKING DEAD SPACES
---	--------------------------	--

Comments: