



October 17, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field Issue of non-continuous post for Lot # 156 Woodside Ridge – 365 NW Patch Ct
Lee's Summit, MO 64081 – Permit # PRRES20222875**

Inspection Comment: Address 6x6 deck post non-continuous per plan.

Recommended modifications:

- **Install a 24" length of CS-16 centered at splice per manufacturer's spec's of non-continuous post.**

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a faint, larger blue ink signature that is partially obscured.

Bradley Huxol, PE

