

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20215573
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081
Inspected On: Tuesday, October 18, 2022
Inspected By: Michael Harkins
Expiration Date: 11/17/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Pending	

Corrective Action Required:

1	Miscellaneous Correction	Sidewalk inspection pending Provide final grade & sod Provide splash blocks Sump shall discharge 36" from foundation Find Manhole cover near ADA ramp
---	-----------------------------	---