

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222875  
Address: 365 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, October 18, 2022

Corrective Action Required:

1	Miscellaneous Correction	Address notched joist rear corner garage at DWV Address 6x6 deck post not continuous per plan { not installed to engineers letter on 10/18/22)
---	--------------------------	---

**Comments:**