

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216532
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, October 18, 2022

Corrective Action Required:

1	Misc	-install light fixtures exterior -raise air admittance valve at kitchen sink -install hardware at grocery door pantry -provide attic access cover garage -install guardrail 2nd floor stairs, no bigger gap than a 4" sphere can pass through -interconnection required of all smokes see basement -provide ledger lags at deck ledger -(2)1/2" through bolts at each post/beam connection at deck
---	------	---

Comments: