## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20214631

Address: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Pavement-Proof Roll Ryan Heckman Passed Tuesday, October 18, 2022

Informational:

1 Misc On 3.21.2022 I observed contractor, ESS conduct a proof roll of pavement chemical stabilization.

Informational:

2 Misc \*\*CURB\*\* Performed proof roll for curbs with Larry from ESS. CMT had 20.92

tons on their truck. Had two small spots that needed to be compacted better.

They dug out and recompacted each spot. Proof roll passed. 3/28/22 ES

Informational:

3 Misc On 5.11.2022 I observed ESS conducting a Proof Roll for asphalt placement

using a CMT 20.69 Ton tandem truck which FAILED due to soft spots in the

pavement where utility fixes had been made.

**Comments:**