

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO 640823507
SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES SUMMIT, MO
640823501 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Ryan Heckman	Passed	Tuesday, October 18, 2022

Informational:

1 Misc

10-13-22 RH. Asphalt base started to be placed today when temperature was 51 degrees and rising. 1 lift of 4" base mix was placed with correct temperatures and rolling method. On site testing was completed with passing results. Surface asphalt will be placed tomorrow.

10-14-22 RH. Surface was placed for parking lot today while temperatures were in compliance.

10-17-22 RH. Surface pavement is completely installed and are just waiting on stripping to occur.

Comments: