

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222155
Address: 520 NE TOWN CENTRE DR, Unit:N, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, October 18, 2022

Corrective Action Required:

1	Misc	Engineer plan shows footing with 2 #5 steel rebars. Shall have engineer to address the 2 fiberglass rebars in lieu of the #5 steel rebars.
---	------	--

Comments: