

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220524
Address: 3530 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, October 18, 2022

Corrective Action Required:

1	Misc	-have engineer address condition of wood trusses that are greyed, sun/water damage that were exposed to weather on ground for multiple month - (LETTER NEEDS TO BE FROM ENGINEER AND NEEDS TO BE SPECIFIC FOR ADDRESS/PERMIT)
---	------	---

Comments: