

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216390
Address: 1705 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, October 18, 2022

Corrective Action Required:

2 Misc

- anchor bolts to be tight see pfh, unfinished basement (Check throughout)
- missing lib in garage
- missing stud pack garage south wall
- fire-block wall to ceiling space in dining area
- tighten all nuts and bolts at beam in living room
- fire blocking at fireplace
- address over notched studs E and W basement wall
- anchor bolts to be in the middle 1/3 of sill plate though out
- fire block stud space to ceiling space rec room E wall
- add blocking to plans under kitchen island to plans
- fire block dead space at grinder pump
- fire block into furr down above bed 4 window at beam
- fire block bed 4 W wall to ceiling space
- fireblock bed 4 closet to ceiling space

Comments: